

Per- and polyfluoroalkyl substances (PFAS) have No Federal Maximum Contaminant Level as of December 31, 2020

Laboratory Method Detection Level (MDL) for PFAS's are

Analytical Units ug/L (ppb) part per billion

PFOS 0.04 or 40 ppt parts per trillion (ng/L) nanograms/liter
PFOA 0.02
PFBS 0.09
PFNA 0.02
PFHpA 0.01
PFHxS 0.03

State of Montana has the following Human Health Standards

Analytical Units ug/L (ppb)

PFOS 0.07 or 70 ppt parts per trillion (ng/L) nanograms/liter
PFOA 0.07

OUR WATER WAS SAMPLED IN MAY 2014 AND NOVEMBER 2014

Well 35 TP (Southgate)

PFOS ND
PFOA ND
PFBS ND
PFNA ND
PFHpA ND
PFHxS ND

Well 3A & 3B EP (South Ave.)

PFOS ND
PFOA ND
PFBS ND
PFNA ND
PFHpA ND
PFHxS ND

Well 17 TP (Momont)

PFOS ND
PFOA ND
PFBS ND
PFNA ND
PFHpA ND
PFHxS ND

Well 32 TP (Arthur Ave.)

PFOS ND
PFOA ND
PFBS ND
PFNA ND
PFHpA ND
PFHxS ND

Well 04 TP (Sommers St.)

PFOS ND
PFOA ND
PFBS ND
PFNA ND
PFHpA ND
PFHxS ND

Well 40A/B/C EP (Haugen)

PFOS ND
PFOA ND
PFBS ND
PFNA ND
PFHpA ND
PFHxS ND

Well 18 TP (Gharrett Ave.)

PFOS ND
PFOA ND
PFBS ND
PFNA ND
PFHpA ND
PFHxS ND